


CITY OF ROCKY RIVER



21012 HILLIARD BLVD.

• ROCKY RIVER, OHIO 44116

• (440) 331-0600

WASTEWATER TREATMENT PLANT
22303 LAKE ROAD
ROCKY RIVER, OHIO 44116
(440) 356-5640
FAX (440) 356-5629

PAMELA E. BOBST
MAYOR

March 10, 2014

May Kay Costello
Director of Safety-Service
City of Rocky River
21012 Hilliard Blvd.
Rocky River, Ohio 44116

Robert P. Kelly, P.E.
Director of Engineering
City of Westlake
27700 Hilliard Blvd.
Westlake, Ohio 44145

Matthew C. Nocella
Collection System Operator
City of Bay Village ✓
350 Dover Center Road
Bay Village, Ohio 44140

Rob Berner
Director of Service and Development
City of Fairview Park
20777 Lorain Road
Fairview Park, Ohio 44126

Scott Thomas
Director of Public Service and Properties
City of Bay Village
350 Dover Center Road
Bay Village, Ohio 44140

RE: 2013 Annual Sanitary Sewer Overflow Report

Ladies & Gentlemen:

Enclosed are two (2) copies of the Rocky River Wastewater Treatment Plant 2013 Annual SSO Report. Please keep one copy for your records and the second copy must be made available to the public. A public notice of the availability of this report (at each of the four City Halls) will be placed in the Pain Dealer within the next two weeks as required by the Ohio EPA. One copy has also been sent to the Ohio EPA Northeast District Office and the Columbus Central Office as required by the Rocky River Wastewater Treatment Plant NPDES Permit 3PE00009*KD. Please notify the availability of this report to appropriate members of each City's administration as you see necessary.

If you have any questions or require more information, please don't hesitate to call me at (440) 895-2593 or 356-5640.

Sincerely,
City of Rocky River

Jeffrey A. Harrington
WWTP Superintendent

Encl.

**SANITARY SEWER OVERFLOW
ANNUAL REPORT**

DATE: 01/31/14

FACILITY NAME: City of Bay Village Sanitary Collection System to RRWWTP

OHIO NPDES PERMIT NO: 3PE00009*KD

PERIOD COVERED BY REPORT: January 1, 2013--December 31, 2013

CONTACT PERSON

NAME: Matthew C. Nocella

TITLE: Class I Laborer, Operator of Record

MAILING ADDRESS:

350 Dover Center Road
Bay Village, OH 44140

TELEPHONE: (440) 871-1221

EMAIL: mnocella@cityofbayvillage.com

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION IN THIS REPORT AND ALL ATTACHMENTS. BASED ON MY INQUIRY OF THOSE PERSONS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION CONTAINED IN THE REPORT, I BELIEVE THAT THE INFORMATION IS TRUE, ACCURATE, AND COMPLETE.



Signature of Official


JANUARY 31, 2014

Date

Class I Laborer, OHEPA WC2-1056736
Title

Enter narrative
analysis of WIB
patterns by location,
frequency and cause.

Total number of WIB calls: 109

Lateral problems: (roots, grease, etc): 103

Mainline problems: 6 -- 3 (roots in main), 3 by weather event surcharge.

Total Sanitary mainline flushing conducted 2013: 37,223 ft (7.05 miles)

PROJECTS COMPLETED:

Wolf Road Aerial Sewer replacement--completed January 2013.

PROJECTS PENDING (2014):

Cahoon Road sanitary replacement project started in November 2013.

As of this report, the project is set for completion in the spring of 2014. The existing 10"/12" line is being replaced with a deeper 24" sewer.

SSO #301 and #302 will be eliminated when this project is complete.